



MITCHELL E. DANIELS, Jr., Governor
STATE OF INDIANA

DEPARTMENT OF HOMELAND SECURITY

J. ERIC DIETZ, EXECUTIVE DIRECTOR

*Indiana Department of Homeland Security
Indiana Government Center South
302 West Washington Street
Indianapolis, IN 46204
317-232-3980*

**INDIANA STATE FIRE MARSHAL –
CONDITIONS THAT MAY RESULT IN THE CLOSURE OF A
FACILITY AT WHICH FIREWORKS ARE SOLD, OFFERED FOR
SALE OR STORED**

- The facility does not have the required Certificate of Compliance from the Division of Fire and Building Safety for the use and the owner or operator of the facility has not submitted the properly completed application within 24 hours of the first inspection.
- The structure being used is not one of the permitted occupancy classifications per IC 22-11-14-4.5.
- Required sprinkler system is missing.
- Required sprinkler system is inoperative and not returned to fully operational status within 24 hours of first inspection.
- Required fire resistive construction for the required occupancy separation is missing.
- Required fire resistive construction for the required occupancy separation is not maintained and not restored to the complete integrity within 24 hours of first inspection.
- Required exits are not provided.
- Blocked / obstructed exits and aisles not made compliant while inspector is on the premises at the time of the first inspection.
- Quantity of fireworks exceeds permitted amount for the location (based on allowed storage height, physical space, and restrictions contained in IC 22-11-14 and the provisions of the 2003 Indiana Building Code) and stock not brought into compliance within 24 hours of the first inspection.
- Flammable liquid fueled equipment is located in the facility and it is not removed while the inspector is present at the time of the first inspection.
- An aggregate number of electrical violations that creates a clear and immediate hazard of death or serious bodily harm to any person other than a trespasser exists and such violations are not corrected while the inspector is present at the time of the first inspection.
- The tent is not flame retardant.
- The tent is larger than 1,500 square feet.
- Any other violation of a fire safety law or building law that creates a clear and immediate hazard of death or serious bodily harm to any person other than a trespasser.

Updated 4/19/2007